

Certificate of Conformity

This is to certify that: Amnitec Ltd (UK)
Abercanaid
Merthyr Tydfi
CF48 1UX
United Kingdom

Holds Certificate Number: CNF 801739

In respect of:

BS EN 1736:2008 Refrigerating systems and heat pumps. Flexible pipe elements, vibration isolators, expansion joints and non-metallic tubes. Requirements, design and installation

Type Samples representative of the products listed have been tested and examined to the relevant requirements of the normative reference listed and have been found to comply with these requirements, as detailed in the related test reports as listed on page 2.



For and on behalf of BSI:

Shahm Barhom, Group Product Certification Director

First Issued: 2024-12-12

Effective Date: 2024-12-12

Latest Issue: 2024-12-12

Expiry Date: 2027-12-11

Page: 1 of 2

Certificate of Conformity

No. CNF 801739

Type Test Report Number: 30062108 and 30062106

Project No.: Q792786

Description	Nominal Diameter	Length	Refrigerant	MOP	Standard
Amnitec Python PE-RT/AL/PE-RT Refrigeration Line Set Pipe System	1/4"	3m to 100m	R32	48.3 bar	BS EN 1736:2008
	3/8"		or		
	1/2"		R410A		
	5/8"		or		
	3/4"		R454B	44.8 bar	
	7/8"				

Notes:

- Tubing maximum temperature is 95°C and working temperature is 71°C.
- Clauses 4.1 General application requirements and 9.3 Requirements for the connection to the refrigeration piping (EN 378-2) are excluded due to application and installation specific requirements.
- Clause 9.2 Joints to pipe is excluded due to product design.

First Issued: 2024-12-12

Latest Issue: 2024-12-12

Effective Date: 2024-12-12

Expiry Date: 2027-12-11

Page: 2 of 2

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request. To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).